

WALK-IN REFRIGERATOR/FREEZER BID SPECIFICATIONS

Columbia Montour AVTS is seeking bids for the replacement of the existing Walk-In Refrigerator/Freezer Unit with the following specifications :

- Refrigerated Boxes for WALK-IN REFRIGERATOR/FREEZER
Walk-In Refrigerator/Freezer to measure: 35'-6-1/2" Long by 15'-5" Wide by 8'-7" High complete with: floor; structural ceiling; Embossed Galvalume (26 GA.) interior and exterior finish.
- (2) Exterior stainless-steel ramps
- (2) 48" by 78" high doors with third hinge
- (2) strip curtains (6) 48" long LED additional lights
- (1) BEZA 015 H8 HT3DB (208-230/3/60) with smart speed Scroll unit, 16500 BTU condensing unit
- (1) BEZA 060 L8 HT3DN (208-230/3/60) condensing unit
- (1) BLP317MA-S1D-SV+ (115/1/60) Smart Evaporator with air defrost and EEV installed
- (1) BLP421LE-S2D SV+ (208-230/1/60) Smart Evaporator with electric defrost and EEV installed.
- 1 ea REFRIGERATED TRUCK - Refrigerated Truck that will be a refrigerator and freezer.
- 1 ea LABOR AND MATERIALS - Labor and Materials for the following:
 - Remove and dispose of the existing walk-in cooler/freezer
 - Receive the new walk-in cooler/freezer into warehouse and check for any damage from shipping
 - Deliver the new walk-in cooler/freezer
 - Erect and install the new walk-in cooler/freezer
 - Provide labor to install related refrigeration and drain lines, electrical work, and setting of condensers
 - Check the operation of both the cooler and freezer and set them to proper operating temperatures.